



## **B. Regulatory Compliance Activities**

### ***1. NYS Fire Inspections***

On March 22, 2006, during an annual inspection visit, the NYS Fire Marshall found multiple violations- most notably in Dana Science Center and the Chemistry department. A total of 206 violations were received, the majority of which were classified as minimal. Some significant violations were also noted, including blocked fire exits, inoperative emergency alarms, egress issues, and hazardous materials issues in labeling and proper storage. The College is given 45 days to correct the findings followed by another inspection by the Fire Marshall. This follow up visit is expected in June, 2006. The facilities staff is working with department chairs and directors to correct the issues. Failure to correct the violations can result in fines assessed to the College. The Committee has requested a full report as to the status of the issues at its first fall meeting.

## **C. Emergency Response Planning**

In November, 2005, the Committee supported and recommended the College's participation in a community wide drill designed to test the College's and various community agency readiness in the event

A third area of focus in preventing and reducing worker's compensation claims has been in the area of slip and fall prevention. The Committee received a best practices document from our worker's compensation insurance carrier and used it to assess areas where we might use some of the identified best practices to reduce the opportunity for slips and falls to occur. Most of the recommended actions will be